

## EXHIBIT "11"

### Building Official Comments

**From:** [Rob Barker](#)  
**To:** [Brad Johnson](#)  
**Subject:** RE: Request for Comments - Markwood East - CUP 3-23  
**Date:** Monday, February 6, 2023 11:36:39 AM

---

Brad,

Sorry I am late on this! I am hoping that there is still time to attach this comment.

1 – Trash disposal facilities to be on an accessible route in accordance with IBC 1104.2. If no trash disposal for accessible units is otherwise provided (toters with independent curbside service) the trash enclosures must be on an accessible route. Note, if crossing a vehicular drive path is required, the crossing must be marked as a crosswalk.

Thanks,

---

**Rob Barker**  
Building Official  
City of Burlington  
360.755.0077

---

**From:** Brad Johnson <[bradmj@burlingtonwa.gov](mailto:bradmj@burlingtonwa.gov)>  
**Sent:** Friday, January 20, 2023 1:08 PM  
**To:** Kim Ohara <[kohara@burlingtonwa.gov](mailto:kohara@burlingtonwa.gov)>  
**Cc:** Craig Cherryholmes <[craigc@burlingtonwa.gov](mailto:craigc@burlingtonwa.gov)>; Annie Avery <[anniea@burlingtonwa.gov](mailto:anniea@burlingtonwa.gov)>; Kelly J. Blaine <[kellyjb@burlingtonwa.gov](mailto:kellyjb@burlingtonwa.gov)>; Rob Barker <[robb@burlingtonwa.gov](mailto:robb@burlingtonwa.gov)>; Ryan Spurrier <[ryans@burlingtonwa.gov](mailto:ryans@burlingtonwa.gov)>; John Abenroth <[johna@burlingtonwa.gov](mailto:johna@burlingtonwa.gov)>; Brian Dempsey <[briand@burlingtonwa.gov](mailto:briand@burlingtonwa.gov)>; Marv Pulst <[marvp@burlingtonwa.gov](mailto:marvp@burlingtonwa.gov)>; Don Erickson <[derickson@burlingtonwa.gov](mailto:derickson@burlingtonwa.gov)>; Geoff Hawes <[ghawes@burlingtonwa.gov](mailto:ghawes@burlingtonwa.gov)>  
**Subject:** Request for Comments - Markwood East - CUP 3-23

Review Team,

We've received an application from Sage Homes NW to construct three additional buildings at the intersection of Stevens and Goldenrod. The plans and application materials are available for review on the K drive at the following location:

K:\PLANNING\CUP\_3-23\_MarkwoodEast\_Apartments

Please email any comments, corrections, or recommended conditions of approval by February 3, 2023.

Thanks,

**Brad Johnson**

Community Development Director

City of Burlington

360-755-9717 (7201)

[bradmj@burlingtonwa.gov](mailto:bradmj@burlingtonwa.gov)